C. G. F. 7]

D. Dis. 463/54.

GOVERNMENT OF COORG

..... File No.....

Serial No.....

195 .

( )

Month and Year of Record.....195

Community Projects. . SUBJECT

Construction of quarts for the Medical officer etc at Bhagmandala

---

Previous References

Later References

WD—218—CGP—4,400—20-7-55.

May be allowed
11/2/55

M. L. C

FINANCE DEPARTMENT.

The type designs may be sanctioned for the construction of quarters for the Irrigation Deptt. at Mercara, Virajpet and Omwarpet and also residential quarters for the officials at Mercara. The designs A or B or C or D may be selected. The Irrigation Deptt. will be asked to send up estimates for each type design. Funds could be made available.

Type B & A may be allowed for S.D.C's and all others of class II.

Type C for clerical & ministerial staff.

Type D for class IV

Estimates may be called for each design

Ask S-E. to get the estimates prepared for all types A, B, C & D separately for each

16/11/55

Please see paras 10 to 12 of these notes 15
Draft letter put up for approval

H801
23.2.55.

Hor
23.2.55.

approved
m/1/55

Ch Secy

Endorsement No.3063 dated the 23rd July, 1955, from the D.C. Coorg. | Pic.

The I.O. Coorg, has submitted an estimate amounting 14
to Rs.10,000/- for the construction of quarters for the S.A.S. at Bhagamandala.

In this connection it may be stated that the designs 15
for these quarters have already been approved by the Govt. Please see para 11 of these notes. These estimates, it is stated, have been prepared after the approved type design. The I.O., however, adds that the superstructure has been slightly modified from the approved design subject to the approval of the Govt.

The D.C. recommends that the estimate may be sanctioned 16
and the expenditure ordered to be debited to C.P. funds.

It is for consideration whether the estimates may be sanctioned subject to approval of the modifications made in the superstructure. F.S. 15-3-55.

For orders.

H801
26.7.55.

Hor
27.7.55.

May be approved and Ch Secy 17
Expenditure sanctioned as above.

hp
28/7/55 M.L.O
EVA
1/8/55. (Mr 7/54)
C.C

18 In the estimate provision has been made for basement and foundation to be in clay and also superstructure to be in brick in clay. The saving on this account is very little. On the other hand in an area where rainfall is heavy clay construction will not be quite safe. Therefore this should be changed over to cement. Instead of using such mixture a lean mixture may be used. If the sand is good, 1:8 mixture or otherwise 1:6. cement to be used. Some ceiling should be provided for the bedrooms, and living rooms. The woodwork in the front should be glazed. The ~~expert~~ estimates may be sanctioned subject to these alterations

Ker
4/8.

4/8/55.

re 6/8

Draft sanction orders pls

9/8

18.8.55.

21/8/55

No.A-5 /3565/CPA-D.Dis.463 /54
Mercara, the // November, 1954.

DESPATCHED.

To The D.O. Coorg.
~~The Superintending Engineer,~~
M.I. Department, ~~Virajpet~~.

Sub:-Community Projects - Construction of a quarters for the Medical Officers, etc., at Bhagamandala.

Sir,

I am directed to state that it has been decided to construct the following buildings at Bhgamandala at a cost not exceeding Rs.25,000/-, in all, under the C.P. Scheme:-

1) A quarters for the Medical Officer.

2) A twin quarters for a Compounder and a Nurse.

2. I am to request you therefore kindly to prepare and submit to this office neeessary detailed plans and estimates ~~and plans~~ for the above two buildings at an early date for the approval of the Govt. The designs recently approved with reference to H.O's and Nurses quarters at Hadapura may be adopted in this case also

Yours faithfully,

Ch. Secy.

Copy to the D.C., Coorg, for information.

4/11/54

4.11.54

IMMEDIATE

GOVERNMENT OF COORG
IRRIGATION DEPARTMENT.

SID.No.1494/55. Virajpet, the 20th January 1955.

From - The Superintending Engineer,
Irrigation Department,Coorg,
VIRAJPET.

To The Finance Secretary to the Govt. of Coorg,
XXXXXX MERCARA.

Sir,

Sub: Type designs for quarters for Asst.Surgeon,Sub-Asst. Surgeon, Nurses, Compounders, Servants.

I write to enclose herewith a plan showing the type design for quarters for Asst. Surgeon,Sub-Asst. Surgeon, Nurses, Compounders and Servants, for kind information.

COORG GOVERNMENT SECRETARIAT. F.4/4752. 21 JAN 1955

Type A - Assistant Surgeon.

Type B - Sub-Asst.Surgeon.

Type c - Nurses & Compounders.

Type D - Servants.

Yours faithfully,

20/1/55

SUPT. ENGINEER,
IRRIGATION DEPARTMENT.COORG.

Copy to Development Commissioner, Community Projects, Coorg, Mercara, for kind information.

P.T.O.

No. 1638/55

4.2.55.

Transmitted to the Finance Secretary to Govt. of Mysore the changes suggested by Minister for Law and order have been incorporated in the draft enclosed now. Similar changes have been sent to Rajasthan Govt. for adoption

S. E. 4/2/55

Encl. 1 B.P.

F4

GOVERNMENT SECRETARIAT COORG

7 - FEB 1955

No. A-5-20558/D-Dis. 463/54.

Heroara, the 1st ~~February~~ March 55.

DESPATCH

To

The S.E. H.D. Department-
Vijaypal.

Sub:- Type designs for quarters for Asst. Surgeons, Sub-Asst. Surgeons, Nurses, Compounders, etc

---

Sir,

I am directed to refer to your letter No. 1494/55 dated the 20th January 1955 on the above subject and to state that the type designs, A to D are approved for adoption as follows:-

1) Type B+A — For S.D.O's and and all officers of class II

2) Type C — For clerical or ministerial staff

3) Type D — For class IV officers

2. I am to request you kindly to get the detailed estimates prepared for all types separately and forward the same to this office for the orders of the Govt

3. The blue prints are returned herewith.

Yours faithfully

Ch Secy

H801

22.2.55 for 23.2.55

MINOR IRRIGATION DEPARTMENT

No. 1698

Office of the Irrigation Officer Coorg,
Mercara, dated 26-7-1955

From

THE IRRIGATION OFFICER, COORG,
MERCARA.



To

The Development Commissioner,
Community Projects, Coorg, Mercara.

Sir,

Subject:- Construction of quarters for Sub Assistant Surgeon at Bhagamandala -

Reference:- Your No. 1692/CPA-55 dated 8-6-1955.

Estimate No. 61/55-56 - Amount of Estimate Rs. 10,000/

I write to enclose herewith an estimate for the above construction for favour of sanction at an early date.

The Superstructure is slightly modified from the approved type Design and this may kindly be approved.

Yours faithfully,

Encl:- 1. Report.
2. Estimates.
3. Drawings.

IRRIGATION OFFICER,
COORG.

BSB/19-7.

Please check whether there is provision.

R. 3063 at 23.7.55

Transmitted to the Chief Secretary to the Govt of Coorg for favour of sanctioning Rs 10,000/- for the construction of quarters for Sub Assistant Surgeon Bhagamandla. The expenditure may be debited to the head, 63-B - Community Development Projects - (i) Community Projects - (E) Health and Rural Sanitation - Works. Necessary estimate was got prepared as per your letter No. A.S/3941/CPA.D Dev. 108/54 dt. 3.6.55 × Not-found-up



Development Commissioner

21/7/55 ACoK 21/7/55

21/7

No.A-5 9647 /CPA-D.Dis.463/54
Mercara, the 25 August, 1955.

Sub:-Community Projects - Construction of quarters for Sub-Assistant Surgeons at Bhagamandala - Expenditure sanction of

---

ORDER.

Sanction is accorded to incur an expenditure not exceeding Rs.10,000/-(Rupees ten thousand) for the construction of quarters for the Sub-Assistant Surgeon at Bhagamandala.

2. The expenditure will be debited to the head " 63-B-Community Development Projects, National Extension Service and Local Development Works - (1) Community Development Projects - E.Health and Rural Sanitation - 4.Works" in the Coorg State Budget for the year 1955-56.

By Order of the C.C.

Ch. Secy.

To

The A.G., Mysore, through the Fin.Dept

The D.C., Coorg, with ref. to his endt No.3063 dated 23-7-55. The estimate is sanctioned with the following observations:-

In the estimate provision has been made for basement and foundation to be in clay and also superstructure to be brick in clay. The savings on this account is very little. On the other hand in an area where rainfall is heavy clay construction will not be quite safe. Therefore this should be changed over to cement. Instead of using rich mixture, a weak mixture may be used. If the sand is good, 1:8 mixture or otherwise 1:6 should be used. Some ceiling should be provided for the bed rooms and living rooms. The verandah in front should be glazed.

Not to appear in the original.

The ~~H.O./~~ E.E in charge S.M.D., Coorg, with ref. to his letter No.1698 dated 20-7-55. The estimate is returned herewith duly sanctioned subject to above conditions.

The T.O./Fin Deptt/S.M.O./Bill Clerk.

1885